

香港特別行政區
《2017年水務設施(修訂)規例》小組委員會
主席梁志祥議員

梁主席：

對《2017年水務設施(修訂)規例》的擬議修訂

對《2017年水務設施(修訂)規例》(《規例》)，本人與專業團體法政匯思和前線科技人員討論後，建議對《規例》作以下修訂，並希望政府當局或小組委員會接納。以下為建議修訂條文的英文本。

1. 修訂第 20(2)條

建議修訂為：

- “(2) A departure from a prescribed specification for a pipe or fitting does not amount to non-compliance with the specification for the pipe or fitting may be permitted by the Water Authority only if the departure does not, ~~in the opinion of the Water Authority,~~ adversely affect—
- (a) the efficiency of the fire service or inside service in which the pipe or fitting is installed in providing a reliable and adequate supply of water; and
 - (b) the quality of the water.”.

2. 建議修訂第 20 條(3)

“, inspect, examine, ~~or~~ test or request and inspect any test reports of a pipe or fitting to ascertain whether it complies with a prescribed specification.”

3. 建議修訂第 25 條

建議修訂為：

- “(2) Despite a requirement in Schedule 2 for a pipe or fitting to comply with a prescribed specification, the Water Authority may approve the installation of a pipe or fitting that does not comply with the

specification provided that such installation does not, adversely affect—

(a) the efficiency of the fire service or inside service in which the pipe or fitting is installed in providing a reliable and adequate supply of water; and

(b) the quality of the water.”.

4. 建議修訂第 1 部第 23 段

建議修訂為：

“23. Non-metallic materials and products, including but not limited to lubricants, silicone sealing rings, elastomers sealings rings etc., for use in contact with water intended for human consumption must comply with the relevant requirements in BS 6920-1:2014, BS 6920-2.1:2014, BS 6920-2.2.1:2000+A3:2014, BS 6920-2.2.2:2000+ A1:2014, BS 6920-2.2.3:2000+A2:2014, BS 6920-2.3:2000+ A1:2014, BS 6920-2.4:2000+A1:2014, BS 6920-2.5:2000+ A2:2014, BS 6920-2.6:2000+A2:2014 and BS 6920-3:2000.”

5. 建議第 2 部加入第 22 段

建議加入為：

“22. Non-metallic materials and products, including but not limited to lubricants, silicone sealing rings, elastomers sealings rings etc., for use in contact with water intended for human consumption must comply with the relevant requirements in BS 6920-1:2014, BS 6920-2.1:2014, BS 6920-2.2.1:2000+A3:2014, BS 6920-2.2.2:2000+ A1:2014, BS 6920-2.2.3:2000+A2:2014, BS 6920-2.3:2000+ A1:2014, BS 6920-2.4:2000+A1:2014, BS 6920-2.5:2000+ A2:2014, BS 6920-2.6:2000+A2:2014 and BS 6920-3:2000.”

6. 建議第 4 部加入第 12 段

“12. A water heater sold, installed or manufactured for the purpose of

human consumption of the drinking water must not be made of metallic, non metallic or solder materials that may adversely affect the water quality.”

以上建議，謹供政府當局及委員會考慮。

立法會議員黃碧雲
2017年6月27日