

By post and by email at sc_subleg@legco.gov.hk

14 July 2021

Clerk to Subcommittee on Fire Service (Installations and Equipment) (Amendment)
Regulation 2021
Legislative Council Secretariat
Legislative Council Complex
1 Legislative Council Road
Central, Hong Kong

Dear Sir/Madam

**Views from The Hong Kong Institution of Engineers
on the Amendment of the Fire Service (Installations and Equipment)
(Amendment) Regulation (Cap. 95B)**

On behalf of the Institution, I am pleased to present to you our views and suggestions as set out in the enclosure for your kind consideration on the captioned subject.

With our expertise and experience, the Institution welcomes the opportunity to work with the Government on the area of concern if and when it is needed.

Thank you.

Yours faithfully



Ir Edwin CHUNG
President

EC/CKH/EK/SS

Enclosure

**Views from The Hong Kong Institution of Engineers
regarding the Amendment of the Fire Service (Installations and Equipment)
(Amendment) Regulation (Cap. 95B)**

The Hong Kong Institution of Engineers (HKIE) would like to provide the following views regarding the amendment of the Fire Service (Installations and Equipment) (Amendment) Regulations (Cap. 95B) for the Subcommittee's consideration:

2. The Institution supports adding a new definition of "stand-alone fire detector" and the amendment to exclude it from the provision of regulations 6(1) and 7(1) of the (IE) Regulation, as well as the provision of regulation 8 of the same regulation.